

DISTRICT PUBLIC HEALTH LAB
DISTRICT CIVIL HOSPITAL, GURUGRAM

D.No. 96/1025/mico

Dated 12/5/2025

To

The S.M.O./M.O. Incharge,

CHC/~~DHC~~ Farukhnagar

SUB : WATER SAMPLES REPORT

In reference to your letter No. 6

Dated 10/5/2025 vide which you have sent water samples for bacteriological examination, the result of each is as under :

Sr. No.	Place of Collection	Result	PCC
1.	Village Swari (Panchayat Tubewell)	FIT	2/10ml Class II
2.	Raj Mala Sees School Farukhnagar (Tubewell)	FIT	2/10ml Class II
3.			
4.			
5.			

P.C.C. Presumptive coliforms count

* Above samples are tested by multiple tube methods.

INTERPRETATION

PCC Per 100ml	CLASS	REMARK	RESULT
0	I	EXCELLENT	FIT
1 - 3	II	SATISFACTORY	FIT
4 - 9	III	SUSPICIOUS	UNFIT
> 9	IV	UN SATISFACTORY	UNFIT

* The Result given above are related to samples as received & tested in Lab..

Dr. Manish Bhat
Dr. Manish Bhat
MBBS, M.D. Microbiology
Medical Officer
Civil Hospital, Gurugram
MCI - 11-40072

(MICROBIOLOGIST)
D.C.H., Gurugram